



**Certificate No.:**  
525226  
LP Gas - Domestic



**CERTIFICATE OF CONFORMITY FOR GAS INSTALLATIONS: OCCUPATIONAL HEALTH AND SAFETY ACT, 1993 Regulation 17(3) of the Pressure Equipment Regulations, 2009**

<b>Company Name :</b>	CN Sibiya		
Physical Address :	3 Slayton	ERF Number:	2723
Province :	KwaZulu-Natal	Town :	Empangeni
Postal Code :	3880		

**User/Owner's Details**

Name & Surname :	CN Sibiya	Capacity :	Owner
Cell No. :	0824632017	Email Address :	x.buthelezi@buthelezizungu.co.za

**Certificate Received By**

Name & Signature :	CN Sibiya	<b>Signature :</b>	-

**Gas Practitioner's Details**

Name & Surname :	Nicolaas Hattingh	<b>SAQCC Gas Reg no:</b>	5396
Cell No.:	27767027883	Email Address:	1@lpgasexperts.co.za
Company :	Energy Provider CC	Tel No.:	035 753 1286
Practitioner Type:	Permanent	LPGSA Reg No:(If any)	

**Practitioner's Signature:**

Date	10-09-25	Job Card	22324
------	----------	----------	-------

Declaration: I Nicolaas Hattingh declare that I am an authorised person and confirm that the information provided is correct.



**Certificate No.:**

525226

LP Gas - Domestic



**CERTIFICATE OF CONFORMITY FOR GAS INSTALLATIONS: OCCUPATIONAL HEALTH AND SAFETY ACT, 1993 Regulation 17(3) of the Pressure Equipment Regulations, 2009**

Type of Installation :	Domestic
Reason for Issue of Certificate :	Repair to Installation
Previous CoC number issue for the Site if Applicable :	0

Cylinder Size	Quantity	Cylinder / Tank Details	
19	1	Weight (Kg)	19
		Volume (Ltrs)	38
		Fire Approval if Required (Yes/No)	no

**Manifolds**

Manifold Type	Vapor/Liquid(Name)	Serial No.	Type
Vapor		0	0

**Regulator Brand**

Regulator Brand Name	Model Number	Quantity
Safegas	2.8kpa	1

**Pipework Type**

Pipetype	Steel	Copper	Composite	CSST	HDPE
Surface			2		
Embedded					
In Roof					
Buried				5	
Filling Site					
Pipe run in metre	0	0	2.0	5.0	0

**Appliances**

**Note: for domestic and commercial installations, only appliances that comply with SANS 1539 may be installed. If in doubt contact the appliance supplier or the LPGSA**

Type Name	Brand	Model Number
Hob5 Burner	Defy	DHG109

<b>Installation Standard</b>	Sans10087-1
<b>Edition</b>	7
Leak test	Pass
Leak Repaired	NA
Static Pressure	3.1kpa



**Certificate No.:**

525226

LP Gas - Domestic



**CERTIFICATE OF CONFORMITY FOR GAS INSTALLATIONS: OCCUPATIONAL HEALTH AND SAFETY ACT, 1993 Regulation 17(3) of the Pressure Equipment Regulations, 2009**

Working Pressure	2.8kpa
Metered site	No
Flue Termination	Flueless
Flue Operation Tested	Flueless
Ventilation	Pass
Burner Inspection	Pass
Burner Cleaned	NA
Flame Picture	Pass
Appliance operation	Pass
Manifold Inspection	N/A
Manifold Repair	0

**Uploaded Supporting Documents :**

--	--	--	--	--

**Geo Locations of COC**    Latitude :-28.789228    Longitude : 32.095775

<b>Mentor Name (if Applicable)</b>	<b>Signature (if Applicable)</b>
Mentor Registration ID (if Applicable)	

<b>Additional comments (if any)</b>	0
-------------------------------------	---

**CERTIFICATE OF CONFORMITY FOR GAS INSTALLATIONS: OCCUPATIONAL HEALTH AND SAFETY ACT, 1993 Regulation 17(3) of the Pressure Equipment Regulations, 2009**

**Safety Concern/Comments**

0

In the event of a gas leak, close all valves, open windows and contact your gas installer or supplier




**Adhere** to all warning signs fitted to the gas installation and cylinders


It is advisable to install at least one dry powder fire extinguisher **close to** the LP Gas cylinder installation



When storing certain volumes of LP Gas on your premises, the local by-laws might require that you obtain a Flammable Liquid Permit (check with your gas supplier/ Fire Department)




Do not make changes or additions to the gas installation. Only use a registered gas installer



Ensure the cylinder valve is **closed** before removing the connecting hose or changing the gas cylinder



The installation is equipped with an emergency valve that must be accessible at all times should an emergency arise



Ensure that the main isolation valve of the gas supply line is **closed** when the system is not in use for extended periods

**Permanent air ventilation may be required for the safety of the occupants of rooms where gas appliances are installed. Check with the gas installer**

**Empty Cylinders must be closed and stored in a safe place away from extreme heat**

**All gas installations and appliances should be checked for leaks and safe operation every 12 months**

**LP Gas hoses to connect cylinders must be replaced every 5 years or sooner if they show any cracks in the surface**