



Certificate No.:

606761

LP Gas - Domestic



CERTIFICATE OF CONFORMITY FOR GAS INSTALLATIONS: OCCUPATIONAL HEALTH AND SAFETY ACT, 1993 Regulation 17(3) of the Pressure Equipment Regulations, 2009

Company Name :	Chops Family Investments		
Physical Address :	15 Marie Street	ERF Number:	569
Province :	Gauteng	Town :	Meyerton
Postal Code :	1929		

User/Owner's Details

Name & Surname :	Kenny Willemse	Capacity :	Representative
Cell No. :	0713546460	Email Address :	kenny@cfinvestment.org

Certificate Received By

Name & Signature :	Kenny Willemse	Signature :	

Gas Practitioner's Details

Name & Surname :	Nick Kriel	SAQCC Gas Reg no:	409/R
Cell No.:	27835987809	Email Address:	Nico.kriel@hotmail.com
Company :	Independent Contractor	Tel No.:	0835987809
Practitioner Type:	Permanent	LPGSA Reg No:(If any)	

Practitioner's Signature:

Date	26-03-26	Job Card	782
-------------	----------	-----------------	-----

Declaration: I Nick Kriel declare that I am an authorised person and confirm that the information provided is correct.

CERTIFICATE OF CONFORMITY FOR GAS INSTALLATIONS: OCCUPATIONAL HEALTH AND SAFETY ACT, 1993 Regulation 17(3) of the Pressure Equipment Regulations, 2009

Type of Installation :	Domestic
Reason for Issue of Certificate :	Change of Ownership with no modification
Previous CoC number issue for the Site if Applicable :	0

Cylinder Size	Quantity	Cylinder / Tank Details	
Selling without Cylinders	0	Weight (Kg)	0
		Volume (Ltrs)	0
		Fire Approval if Required (Yes/No)	No

Manifolds

Manifold Type	Vapor/Liquid(Name)	Serial No.	Type
Vapor		N/A	0

Regulator Brand

Regulator Brand Name	Model Number	Quantity
Astro 4kg	704-28	1

Pipework Type

Pipetype	Steel	Copper	Composite	CSST	HDPE
Surface			15.7		
Embedded					
In Roof					
Buried					
Filling Site					
Pipe run in metre	0	0	15.7	0	0

Appliances

Note: for domestic and commercial installations, only appliances that comply with SANS 1539 may be installed. If in doubt contact the appliance supplier or the LPGSA

Type Name	Brand	Model Number
6l Gas Geyser Type B	Atlas	12EC
5 Burner Gas/Gas Stove	Telefunken	TGEO-900S

Installation Standard SANS 10087-1

Edition 2013

Leak test Pass

Leak Repaired NA

CERTIFICATE OF CONFORMITY FOR GAS INSTALLATIONS: OCCUPATIONAL HEALTH AND SAFETY ACT, 1993 Regulation 17(3) of the Pressure Equipment Regulations, 2009

Static Pressure	2.8kpa
Working Pressure	2.8kpa
Metered site	No
Flue Termination	Pass
Flue Operation Tested	Pass
Ventilation	Pass
Burner Inspection	Pass
Burner Cleaned	NA
Flame Picture	Pass
Appliance operation	Pass
Manifold Inspection	N/A
Manifold Repair	N/A

Uploaded Supporting Documents :



Geo Locations of COC Latitude :-26.729715 Longitude : 27.829383

Mentor Name (if Applicable)	Signature (if Applicable)
	-
Mentor Registration ID (if Applicable)	
Additional comments (if any)	

CERTIFICATE OF CONFORMITY FOR GAS INSTALLATIONS: OCCUPATIONAL HEALTH AND SAFETY ACT, 1993 Regulation 17(3) of the Pressure Equipment Regulations, 2009

Safety Concern/Comments

None

In the event of a gas leak, close all valves, open windows and contact your gas installer or supplier



Adhere to all warning signs fitted to the gas installation and cylinders

It is advisable to install at least one dry powder fire extinguisher **close to** the LP Gas cylinder installation




When storing certain volumes of LP Gas on your premises, the local by-laws might require that you obtain a Flammable Liquid Permit (check with your gas supplier/ Fire Department)



Do not make changes or additions to the gas installation. Only use a registered gas installer




Ensure the cylinder valve is **closed** before removing the connecting hose or changing the gas cylinder



Open

The installation is equipped with an emergency valve that must be accessible at all times should an emergency arise



Closed

Ensure that the main isolation valve of the gas supply line is **closed** when the system is not in use for extended periods

Permanent air ventilation may be required for the safety of the occupants of rooms where gas appliances are installed. Check with the gas installer

Empty Cylinders must be closed and stored in a safe place away from extreme heat

All gas installations and appliances should be checked for leaks and safe operation every 12 months

LP Gas hoses to connect cylinders must be replaced every 5 years or sooner if they show any cracks in the surface