



Certificate No.:
543845
LP Gas - Domestic



CERTIFICATE OF CONFORMITY FOR GAS INSTALLATIONS: OCCUPATIONAL HEALTH AND SAFETY ACT, 1993 Regulation 17(3) of the Pressure Equipment Regulations, 2009

Company Name :	PRIVATE ESTATE		
Physical Address :	23 Joslyn Crescent, Fourleaf Estate, Parsonsvlei	ERF Number:	5320
Province :	Eastern Cape	Town :	PORT ELIZABETH
Postal Code :	6045		

User/Owner's Details


Name & Surname :	Marnic Esterhuizen- Newland-Nell	Capacity :	OWNER
Cell No. :	0647506200	Email Address :	marnic@hotmail.co.za

Certificate Received By

Name & Signature :	Marnic Esterhuizen- Newland-Nell	Signature :	

Gas Practitioner's Details

Name & Surname :	Izak van der Merwe	SAQCC Gas Reg no:	368/R
Cell No.:	27761019001	Email Address:	mrgas@vodamail.co.za
Company :	Mr Gas	Tel No.:	0761019001
Practitioner Type:	Permanent	LPGSA Reg No:(If any)	

Practitioner's Signature:			
Date	24-10-25	Job Card	0

Declaration: I Izak van der Merwe declare that I am an authorised person and confirm that the information provided is correct.



Certificate No.:

543845

LP Gas - Domestic



CERTIFICATE OF CONFORMITY FOR GAS INSTALLATIONS: OCCUPATIONAL HEALTH AND SAFETY ACT, 1993 Regulation 17(3) of the Pressure Equipment Regulations, 2009

Type of Installation :	Domestic
Reason for Issue of Certificate :	New Installation
Previous CoC number issue for the Site if Applicable :	0

Cylinder Size	Quantity	Cylinder / Tank Details	
9KG	1	Weight (Kg)	9
		Volume (Ltrs)	9
		Fire Approval if Required (Yes/No)	N/A

Manifolds

Manifold Type	Vapor/Liquid(Name)	Serial No.	Type
Vapor		N/A	N/A

Regulator Brand

Regulator Brand Name	Model Number	Quantity
ASTRO	4KG/K	1

Pipework Type

Pipetype	Steel	Copper	Composite	CSST	HDPE
Surface			4		
Embedded					
In Roof					
Buried					
Filling Site					
Pipe run in metre	0	0	4.0	0	0

Appliances

Note: for domestic and commercial installations, only appliances that comply with SANS 1539 may be installed. If in doubt contact the appliance supplier or the LPGSA

Type Name	Brand	Model Number
GAS GEYSER	TOTALI	12LT

Installation Standard	SANS 10087/1
Edition	7/2024
Leak test	Pass
Leak Repaired	NA
Static Pressure	2.8KPA



Certificate No.:

543845


LP Gas - Domestic



CERTIFICATE OF CONFORMITY FOR GAS INSTALLATIONS: OCCUPATIONAL HEALTH AND SAFETY ACT, 1993 Regulation 17(3) of the Pressure Equipment Regulations, 2009

Working Pressure	2.8KPA
Metered site	No
Flue Termination	Pass
Flue Operation Tested	Pass
Ventilation	Pass
Burner Inspection	Pass
Burner Cleaned	NA
Flame Picture	Pass
Appliance operation	Pass
Manifold Inspection	N/A
Manifold Repair	N/A

Uploaded Supporting Documents :



Geo Locations of COC Latitude :-33.929329 Longitude : 25.470301

Mentor Name (if Applicable)	Signature (if Applicable)
Mentor Registration ID (if Applicable)	

Additional comments (if any)	NEW TEST POINT FITTED
-------------------------------------	-----------------------

CERTIFICATE OF CONFORMITY FOR GAS INSTALLATIONS: OCCUPATIONAL HEALTH AND SAFETY ACT, 1993 Regulation 17(3) of the Pressure Equipment Regulations, 2009

Safety Concern/Comments

NO

In the event of a gas leak, close all valves, open windows and contact your gas installer or supplier




Adhere to all warning signs fitted to the gas installation and cylinders


It is advisable to install at least one dry powder fire extinguisher **close to** the LP Gas cylinder installation



When storing certain volumes of LP Gas on your premises, the local by-laws might require that you obtain a Flammable Liquid Permit (check with your gas supplier/ Fire Department)




Do not make changes or additions to the gas installation. Only use a registered gas installer



Ensure the cylinder valve is **closed** before removing the connecting hose or changing the gas cylinder



The installation is equipped with an emergency valve that must be accessible at all times should an emergency arise



Ensure that the main isolation valve of the gas supply line is **closed** when the system is not in use for extended periods

Permanent air ventilation may be required for the safety of the occupants of rooms where gas appliances are installed. Check with the gas installer

Empty Cylinders must be closed and stored in a safe place away from extreme heat

All gas installations and appliances should be checked for leaks and safe operation every 12 months

LP Gas hoses to connect cylinders must be replaced every 5 years or sooner if they show any cracks in the surface